

LEED - EAc5 - Measurement and Verification																			
Requirement	Information provided by the DES company																		
Information about the measured amount of energy delivered to the building from the DES has to be given to the LEED seeking project	1) Heat delivered [MWh/year]																		
	Fylls i av kund Lev. Fjärrvärme: MWh Lev Fjärrkyla: MWh																		
Amount (in energy terms) and type of fuel used for heat production in heat only boilers (HOB).	1) Fuel i_n (all fuels) [MWh/year]																		
	<table border="1"> <thead> <tr> <th>Bränsletyp</th> <th>Tillfört MWh</th> </tr> </thead> <tbody> <tr><td>Bioolja</td><td>664 813</td></tr> <tr><td>El</td><td>757 013</td></tr> <tr><td>Fossilolja</td><td>101 143</td></tr> <tr><td>Förädlat Trädbränsle</td><td>2 090</td></tr> <tr><td>Oförädlat Trädbränsle</td><td>1 522 656</td></tr> <tr><td>Övriga</td><td>1 277 472</td></tr> <tr><td>Övriga Biobränsle</td><td>3 374</td></tr> </tbody> </table>	Bränsletyp	Tillfört MWh	Bioolja	664 813	El	757 013	Fossilolja	101 143	Förädlat Trädbränsle	2 090	Oförädlat Trädbränsle	1 522 656	Övriga	1 277 472	Övriga Biobränsle	3 374		
Bränsletyp	Tillfört MWh																		
Bioolja	664 813																		
El	757 013																		
Fossilolja	101 143																		
Förädlat Trädbränsle	2 090																		
Oförädlat Trädbränsle	1 522 656																		
Övriga	1 277 472																		
Övriga Biobränsle	3 374																		
Amount (in energy terms) and type of fuel used in each combined heat and power (CHP) plant in the DES.	1) Fuel i_n (all fuels) [MWh/year]																		
	<table border="1"> <thead> <tr> <th>Bränsletyp</th> <th>Tillfört MWh</th> </tr> </thead> <tbody> <tr><td>Avfallsbränsle</td><td>1 301 837</td></tr> <tr><td>Bioolja</td><td>226 749</td></tr> <tr><td>El</td><td>219 902</td></tr> <tr><td>Fossilolja</td><td>88 402</td></tr> <tr><td>Förädlat Trädbränsle</td><td>550 006</td></tr> <tr><td>Oförädlat Trädbränsle</td><td>556 257</td></tr> <tr><td>Returbränsle</td><td>1 275 379</td></tr> <tr><td>Övriga</td><td>828</td></tr> </tbody> </table>	Bränsletyp	Tillfört MWh	Avfallsbränsle	1 301 837	Bioolja	226 749	El	219 902	Fossilolja	88 402	Förädlat Trädbränsle	550 006	Oförädlat Trädbränsle	556 257	Returbränsle	1 275 379	Övriga	828
Bränsletyp	Tillfört MWh																		
Avfallsbränsle	1 301 837																		
Bioolja	226 749																		
El	219 902																		
Fossilolja	88 402																		
Förädlat Trädbränsle	550 006																		
Oförädlat Trädbränsle	556 257																		
Returbränsle	1 275 379																		
Övriga	828																		
Specific primary energy factors, PEF, for fuels that the DES-company uses compared to those suggested in Swedish DES-guide, table 5 in Appendix A. If the PEF differs an explanation why is needed.	1) $PEF_{HOB(i)}$ and $PEF_{CHP(i)}$ (specific fuels) [kWh_p/kWh_{fuel}]																		
	<table border="1"> <thead> <tr> <th>PEF Stockholm Exergi (VMK)</th> <th></th> <th>Swedish DES calculation method</th> </tr> </thead> <tbody> <tr><td>Eo1</td><td>1,11</td><td>1,11</td></tr> <tr><td>Eo5</td><td>1,11</td><td>1,11</td></tr> <tr><td>Kol</td><td>1,15</td><td>1,15</td></tr> <tr><td>Secondary biofuels</td><td>0,03</td><td>1,05</td></tr> <tr><td>Wooden pellets etc</td><td>0,11</td><td>1,05</td></tr> </tbody> </table>	PEF Stockholm Exergi (VMK)		Swedish DES calculation method	Eo1	1,11	1,11	Eo5	1,11	1,11	Kol	1,15	1,15	Secondary biofuels	0,03	1,05	Wooden pellets etc	0,11	1,05
PEF Stockholm Exergi (VMK)		Swedish DES calculation method																	
Eo1	1,11	1,11																	
Eo5	1,11	1,11																	
Kol	1,15	1,15																	
Secondary biofuels	0,03	1,05																	
Wooden pellets etc	0,11	1,05																	

	Biooil	0,04	0,03
	Household waste	0,04	0,03
	Return fuel*	0,05	0,03
	Electricity unspec. Nordic mix	2,46	1,90
	Electricity origin labeled	0	-
	Waste heat	0	0,00
	Energy from sea and sewer	0	-
	<p>*Return fuels consist of sorted and quality-controlled paper, wood and plastic that cannot be recycled and come from offices, shops and industries</p> <p>The biggest difference is that tiles and wood pellets according to VMK (as used by Stockholm Exergi) are considered secondary fuels while Swedish DES Calc. Meth blends biofuels into a primary fuel mail.</p> <p>Additional PEF can be found in the appendix to the "Överenskommelse i värmemarknadskommittén 2020"</p>		
Total amount of produced heat in the specific combined heat and power plant.	1) Heat produced [MWh/year]		
	5 065 000 MWh		
Total amount of produced electricity, without deduction of auxiliary electricity, in the specific combined heat and power plant.	1) Electricity produced [MWh/year]		
	979 000 MWh		
The total delivered district heating to all customers in the district heating network.	1) Heat delivered [MWh/year]		
	Total heating delivered in heating network: 7 281 000 MWh		
For district cooling additional information is needed. That is;			
The amount of electricity used to produce the cooling (including both the auxiliary electricity for circulation of the cold water in the DES and the electric energy needed for the heat pumps).	1) Auxiliary electricity [MWh/year]		
	Pumpel 19 369		
	2) Electricity used in combined heat pumps [MWh/year]		
	Combined heat pumps and refrigerating machines: 62 412		
Produced heat and cooling in heat pumps	1) Total produced Heat [MWh/year]		
	1 930 000 MWh		
	2) Total produced cooling [MWh/year]		

	<p>360 000 MWh</p> <p>(Incl. Combined heat pumps, Free cooling, Cooling machines Waste cooling)</p>
<p>The amount of heat energy used to produce cooling in absorption chillers. In best case monthly amounts are used and summarized for one year.</p>	<p>1) Heat month, Jan - Dec [MWh/month]</p>
	<p><i>Fortum does not have any absorption chillers in its network.</i></p>
	<p>2) Monthly Production Scheme [Fuel type, MWh, production type]</p>
	<p><i>Fortum does not have any absorption chillers in its network.</i></p>